

## METROPOLITAN GOVERNMENT OF NASHVILLE AND DAVIDSON COUNTY

Metro Office Building 800 President Ronald Reagan Way P.O. Box 196300 Nashville, TN 37219-6300

March 10, 2023

To: Edward Thurman Metro Water Services

Re: VANDERBILT UNIVERSITY BASKETBALL FACILITY

Planning Commission Mandatory Referral # 2023M-035ES-001

Council District #18 Tom Cash, Council Member

On behalf of the Metropolitan Planning Commission, the following item, referred to the Commission as required by the Metro Charter, has been recommended for *approval* to the Metropolitan Council:

A request for the abandonment of approximately 262 linear feet of 6-inch water main (DIP), 326 linear feet of 16-inch water main (DIP) and one fire hydrant assembly and the acceptance of approximately 296 linear feet of 16-inch water main (DIP) to serve the Vanderbilt University Basketball Facility development.

The relevant Metro agencies (Metro Parks, Metro Public Works, Metro Water Services, Metro Emergency Communications, the Nashville Electric Service, Metro Finance – Public Property and the Metro Historical Commission) have reviewed the proposal and concur in the recommendation for approval. This request must be approved by the Metro Council to become effective. A sketch showing the location of the request is attached to this letter.

Conditions that apply to this approval: Fire hydrant locations shall maintain maximum 100' from fire department standpipe connections (FDC).

This recommendation for approval is given as set forth in the Metropolitan Planning Commission Rules and Procedures. If you have any questions about this matter, please contact Delilah Rhodes at delilah.rhodes@nashville.gov or 615-862-7208.

Sincerely,

Lisa Milligan

Land Development Manager Metro Planning Department

cc: Metro Clerk

## Re: VANDERBILT UNIVERSITY BASKETBALL FACILITY Planning Commission Mandatory Referral # 2023M-035ES-001 Council District #18 Tom Cash, Council Member

A request for the abandonment of approximately 262 linear feet of 6-inch water main (DIP), 326 linear feet of 16-inch water main (DIP) and one fire hydrant assembly and the acceptance of approximately 296 linear feet of 16-inch water main (DIP) to serve the Vanderbilt University Basketball Facility development.



