



Government of Nashville and Davidson County requiring it.

Analysis

This ordinance authorizes the director of the Department of Water and Sewerage Services to execute a settlement agreement and release of liability with CH2M Hill Engineers, Inc. ("CH2M"). Metro retained CH2M to perform engineering work for the Dry Creek WWTP Ultraviolet Disinfection Project.

According to the settlement agreement and release, Metro alleges that errors were made regarding the design height of the UV Channel Influent Gates in this project. Both Metro and CH2M seek to enter into an agreement to resolve these issues. Pursuant to the agreement, Metro would receive a credit of \$53,355 on its final invoice for the project, and Metro would release CH2M from any legal claims that could be made as a result of these errors. No liability was admitted by either party in the agreement.